

PUBLIC NOTICE

Washington Township Municipal Utilities Authority
Forrest Drive Pump Station Replacement
Washington Township, Gloucester County, New Jersey
Project No. 340930-04

The Washington Township Municipal Utilities Authority (WTMUA) is pursuing financial assistance from the New Jersey Environmental Infrastructure Financing Program for the replacement/installation of a new wet well pump station at the existing Forrest Drive location in Washington Township due to station old age and deterioration. The project also includes the construction of 20 linear feet of 10-inch diameter PVC gravity sewer line, the construction of 65 linear feet of 6-inch diameter ductile iron force main, and the demolition of the existing underground dry well / wet well pump station, the existing auxiliary wet well, and the pump station control shelter. The proposed project will not result in the expansion of the sewer service area or an increase in capacity of the Forrest Drive Pump Station.

Based on planning information submitted in support of the proposed action, the Department has determined that this project qualifies for a Level 1 environmental review. The rules provide that this level applies to certain categories of actions that are expected to have little or no adverse environmental impact.

Based on the Level 1 environmental review, the Department has made a decision to approve the planning information for the proposed action. This decision is a part of the financial assistance application process, but is not a commitment of federal or state funds. The proposed project costs are as follows:

<u>Forrest Drive Pump Station Replacement</u>	
Project Cost:	\$985,110
Proposed Loan:	\$985,110

An environmental summary of the proposed action, including the basis for determining that it qualifies for a Level 1 environmental review, is available for review on the WTMUA's web site: wtmua.com